

Coast Guard, DHS

§ 95.05–10

National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030 or go to http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html. Also, it is available for inspection at Coast Guard Headquarters. Contact Commandant (CG-ENG), Attn: Office of Design and Engineering Systems, U.S. Coast Guard Stop 7509, 2703 Martin Luther King Jr. Avenue SE., Washington, DC 20593-7509; telephone 202-372-1405. The material is also available from the sources listed in paragraphs (b) and (c) of this section.

(b) ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959, 877-909-2786, <http://www.astm.org>.

(1) ASTM F1121-87 (Reapproved 2010), Standard Specification for International Shore Connections for Marine Fire Applications, (approved March 1, 2010), incorporation by reference approved for § 95.10-10.

(2) [Reserved]

(c) National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02269-9101, telephone 800-344-3555, <http://www.nfpa.org>.

(1) NFPA 13-1996, Standard for the Installation of Sprinkler Systems, incorporation by reference approved for § 95.30-1.

(2) [Reserved]

[USCG-2009-0702, 74 FR 49232, Sept. 25, 2009, as amended by USCG-2012-0832, 77 FR 59780, Oct. 1, 2012; USCG-2012-0866, 78 FR 13251, Feb. 27, 2013; USCG-2013-0671, 78 FR 60151, Sept. 30, 2013]

§ 95.01-5 Equipment installed but not required.

(a) Where fire detecting or extinguishing systems or equipment are not required, but are installed, the system or equipment and its installation shall meet the requirements of this part.

Subpart 95.05—Fire Detecting and Extinguishing Equipment, Where Required

§ 95.05-1 Fire detecting, manual alarm, and supervised patrol systems.

(a) Fire detecting, manual alarm, and supervised patrol systems are not re-

quired except in special cases; but if installed, the systems shall meet the applicable requirements of part 76 of subchapter H (Passenger Vessels) of this chapter.

(b) In each compartment containing explosives, and in adjacent cargo compartments, there shall be provided a smoke detecting or other suitable type fire detecting system.

(c) Enclosed spaces which are “specially suitable for vehicles” shall be fitted with an approved fire or smoke detecting system.

[CGFR 66-33, 31 FR 15285, Dec. 6, 1966]

§ 95.05-5 Fire main system.

(a) Fire pumps, hydrants, hose, and nozzles shall be installed on the following vessels:

(1) On all self-propelled vessels.

(2) On all barges with sleeping accommodations for more than 12 persons.

(b) The arrangements and details of the fire main system shall be as set forth in subpart 95.10.

§ 95.05-10 Fixed fire extinguishing systems.

(a) Approved fire extinguishing systems may be used or required in locations delineated in this section on the following vessels. Previously approved installations may be retained as long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection.

(1) On all self-propelled vessels other than yachts and fishing vessels.

(2) On all barges with sleeping accommodations for more than 12 persons.

(b) A fixed carbon dioxide or other approved system must be installed in all cargo compartments and tanks for combustible cargo, except for vessels engaged exclusively in the carriage of coal or grain in bulk. For cargo compartments and tanks fitted with a fixed carbon dioxide or other approved system a deck foam system is not required, instead of the carbon dioxide system or other approved system, the following systems may be used or required in special cases:

(1) A fixed foam system may be used in cargo tanks.

(2) A water sprinkling system may be required, and the details of such system will be subject to special approval,